



4320 Midmost Drive Mobile, Alabama 36609  
Phone (251) 344-9106 Fax (251) 341-9492

Report Date: 03/30/15 16:53

Report To: Satsuma Water & Sewer  
P.O.Box 559  
Satsuma, AL 36572  
Attention: Tom Briand

Project: Satsuma Water & Sewer  
Project Number: MS-4 Permit/ MO-01

### ANALYTICAL REPORT

This report includes the results of analyses for the samples listed below that were received by the laboratory on 03/23/15 08:15 . The associated quality control data is not included in this report but is available upon request. If you have any questions concerning this report, please feel free to call Ken Mohr at (251) 344-9106.

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
MO-01	15C0378-01	Stormwater	03/22/15 08:46	03/23/15 08:15
MO-01	15C0378-02	Stormwater	03/22/15 08:36	03/23/15 08:15

Ken Mohr, Customer Service



*The test results in this report meet NELAP requirements for accredited parameters, unless otherwise noted, and relate only to the sample(s) received by this laboratory. This report must be reproduced in its entirety unless approved by the laboratory.*

*Results are reported on a "wet weight basis", unless otherwise noted.*

Satsuma Water & Sewer

Sample Name: MO-01

Sample Date: 03/22/15 08:46

Date Received: 03/23/15 08:15

Sampled by: Ken Mohr

Sample Type: Grab

Matrix: Stormwater

*Reporting*

Analyte	Result	Units	Limit	Analyst	Prepared	Analyzed	Method	Batch	Lab Number
<b><u>Classical Chemistry Parameters</u></b>									
Oil & Grease	< 2	mg/L	2	SAB	03/26/15 08:15	03/27/15 15:00	EPA 1664	5C26005	15C0378-01

Satsuma Water & Sewer

Sample Name: MO-01

Sample Date: 03/22/15 08:36

Date Received: 03/23/15 08:15

Sampled by: Ken Mohr

Sample Type: Composite

Matrix: Stormwater

*Reporting*

Analyte	Result	Units	Limit	Analyst	Prepared	Analyzed	Method	Batch	Lab Number
<b><u>Classical Chemistry Parameters</u></b>									
<b>Biochemical Oxygen Demand</b>	<b>2</b>	mg/L	2	JLM	03/23/15 14:45	03/28/15 09:55	SM 5210B	5C23026	15C0378-02
<b>Chemical Oxygen Demand</b>	<b>70</b>	mg/L	20	JMB	03/30/15 10:20	03/30/15 10:20	SM 5220D	5C30003	15C0378-02
Nitrate as N	< 0.1	mg/L	0.1	JLM	03/23/15 14:15	03/23/15 14:15	EPA 353.2	5C23020	15C0378-02
<b>Phosphorus</b>	<b>0.123</b>	mg/L	0.100	CHR	03/30/15 16:16	03/30/15 16:16	EPA 365.4	5C30025	15C0378-02RE1
Phosphorus (Dissolved)	< 0.100	mg/L	0.100	CHR	03/30/15 16:16	03/30/15 16:16	EPA 365.4	5C30025	15C0378-02RE1
<b>Total Dissolved Solids</b>	<b>87</b>	mg/L	5	JMB	03/24/15 12:15	03/24/15 12:15	SM 2540C	5C23011	15C0378-02
<b>Total Kjeldahl Nitrogen</b>	<b>1.4</b>	mg/L	0.5	CHR	03/30/15 16:12	03/30/15 16:12	EPA 351.2	5C30022	15C0378-02
<b>Total Suspended Solids</b>	<b>36</b>	mg/L	5	JMB	03/23/15 16:05	03/23/15 16:05	SM 2540D	5C23019	15C0378-02



The test results in this report meet NELAP requirements for accredited parameters, unless otherwise noted, and relate only to the sample(s) received by this laboratory. This report must be reproduced in its entirety unless approved by the laboratory.

Results are reported on a "wet weight basis", unless otherwise noted.







